

JH CONSULTING, GROUP, INC
 PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

FIRST DRAW COPPER MONITORING RESULTS

Date Printed 12/22/2020

<u>SAMPLE ID</u>	<u>WATER SUPPLY</u>	<u>CUSTOMER NAME</u>	<u>ADDRESS</u>	<u>DATE COLLECTED</u>	<u>HOURS OF NON USE</u>	<u>COPPER</u>	<u>DATE ANALYZED</u>
2007404	Village of Fultonville	5 Broad St		9/24/2020	9.25	0.0099	10/6/20
2007405	Village of Fultonville	18 Main St		9/24/2020	10	0.0203	10/6/20
2007403	Village of Fultonville	60 Union St		9/24/2020	12.25	0.0343	10/6/20
2007406	Village of Fultonville	4 Montgomery St		9/24/2020	6.5	0.0371	10/6/20
2007407	Village of Fultonville	25 Erie St		9/24/2020	11	0.0488	10/6/20
2007408	Village of Fultonville	44 Main St		9/24/2020	9.25	0.0880	10/6/20
2007402	Village of Fultonville	18 Union St		9/22/2020	6.75	0.102	10/6/20
2007401	Village of Fultonville	18 Upper Franklin St		9/24/2020	9.75	0.114	10/6/20
2007409	Village of Fultonville	19 Propect St		9/24/2020	10	0.115	10/6/20
2007410	Village of Fultonville	7 Ann St		9/24/2020	8.25	0.131	10/6/20

Copper VALUES ARRANGED IN ASCENDING ORDER

90th PERCENTILE COPPER CONCENTRATION (HIGHLIGHTED IN YELLOW) **If value is (greater than) >1.3 mg/l the Action Level is Exceeded**
If value is (less than or equal to) ≤1.3 mg/l you are in Compliance

ies for lead and copper are in mg/L
 ysis performed for JH Consulting Group, Inc by NYS Lab 11549 , The above test procedures meet all the requirements of NELAC and relate only to these samples

JH CONSULTING, GROUP, INC
 PO BOX 705
 NEWTONVILLE, NY 12128
 (518) 785-9839

FIRST DRAW LEAD MONITORING RESULTS

Date Printed 12/22/2020

<u>SAMPLE ID</u>	<u>WATER SUPPLY</u>	<u>CUSTOMER NAME</u>	<u>ADDRESS</u>	<u>DATE COLLECTED</u>	<u>HOURS OF NON USE</u>	<u>LEAD</u>	<u>Date Analyzed</u> <u>Lead</u>
2007403	Village of Fultonville	60 Union St		9/24/2020	12.25	<0.0010	10/6/20
2007404	Village of Fultonville	5 Broad St		9/24/2020	9.25	<0.0010	10/6/20
2007405	Village of Fultonville	18 Main St		9/24/2020	10	<0.0010	10/6/20
2007406	Village of Fultonville	4 Montgomery St		9/24/2020	6.5	<0.0010	10/6/20
2007407	Village of Fultonville	25 Erie St		9/24/2020	11	<0.0010	10/6/20
2007408	Village of Fultonville	44 Main St		9/24/2020	9.25	0.0014	10/6/20
2007409	Village of Fultonville	19 Propect St		9/24/2020	10	0.0017	10/6/20
2007402	Village of Fultonville	18 Union St		9/22/2020	6.75	0.0020	10/6/20
2007410	Village of Fultonville	7 Ann St		9/24/2020	8.25	0.0023	10/6/20
2007401	Village of Fultonville	18 Uppér Franklin St		9/24/2020	9.75	0.0031	10/6/20

LEAD VALUES ARRANGED IN ASCENDING ORDER

90th PERCENTILE LEAD CONCENTRATION (HIGHLIGHTED IN YELLOW) If value is (greater than) >0.015 mg/l the Action Level is Exceeded
 If value is (less than or equal to) ≤0.015 mg/l you are in Compliance

values for lead and copper are in mg/L
 Analysis performed for JH Consulting Group, Inc by NYS Lab 11549 , The above test procedures meet all the requirements of NELAC and relate only to these samples